



OFFICE OF PROCUREMENT SERVICES
315 WEST MAIN STREET, SUITE 416
PO BOX 7800
TAVARES FL 32778-7800

PHONE: (352) 343-9839
FAX: 352) 343-9473

www.lakegovernment.com

ADDENDUM NO. 1

Date: February 19, 2010

Invitation to Bid (ITB) No. 10-0406

Sheriff's Maintenance Facility Improvements

This addendum is being issued to make the following changes, corrections, clarifications or additions to the bidding document. Where the information in this addendum modifies and changes the original bidding documents, the addenda takes precedence over the original documents. **Respondents shall acknowledge receipt of this addendum by completing this form and returning it with the response. Failure to acknowledge this addendum may preclude consideration of the bid proposal award.**

The primary purpose of this addenda is to provide answers to all questions raised by prospective bidders during the bidding process to date. Note that the clarifying information provided herein involves no significant change to the original solicitation. Therefore, the bid due date stated in the original solicitation remains unchanged.

Question 1:

Would the car wash structure require any special permitting?

Response:

Yes. A building permit will be required through the City of Eustis. The 3 sided A-frame carport will utilize 12 gauge framing and 29 gauge steel panels with a 6" concrete slab. The size is 20' x 24' x 12' high (8 side posts with a 4:1 pitch roof). It is to be green in color to match the one standing over the mobile command center. The building permit is \$60.00 plus \$7.00 for every \$1000.00 of construction cost. This structure should be approx. \$4000.00 so the fee for the building permit should be approx. \$90.00. A typical structure can be seen at <http://www.carportsandmore.com/shop/shopexd.asp?id=234>

Question 2:

Would vendor be responsible for cleaning up any contaminated dirt under the current fuel tank?

Response:

No.

Question 3:

Were all restrooms shown on the drawings?

Response:

Yes.

"Earning Community Confidence Through Excellence in Service"

DISTRICT ONE
JENNIFER HILL

DISTRICT TWO
ELAINE RENICK

DISTRICT THREE
JIMMY CONNER

DISTRICT FOUR
LINDA STEWART

DISTRICT FIVE
WELTON G. CADWELL

Question 4:

Was reinforcing material required at the tie-in to the Eustis sewer?

Response:

The tie in manhole located at the corner of Cardinal and McDonald will not need to be lined and is required to be tied into the invert of the manhole.

Question 5:

How late can questions be submitted?

Response:

Five working days prior to the bid due date as stated at the pre-bid conference.

Question 6:

Were all electrical hook-ups to be done by the vendor noted in the specifications?

Response:

A power source for the electrical tie to the grinder station will be provided by the Sheriff's office. The contractor will need to coordinate this with the engineer.

Question 7:

Force main shown on plans, can direct bore be used?

Response:

A direction drill/bore for the force main is acceptable.

Question 8:

Please provide location of power source for the grinder pump.

Response:

There will be a power connection provided at the northwest corner of the maintenance shop for the grinder station power to tie into.

Question 9:

Can we get a size or detail on the oil/water separator?

Response:

Please refer to sheet 7 on the plans where dimensions are depicted and specific details can come from the manufacturer stated next to the drawing.

Firm Name: _____ Date: _____

Signature: _____ Title: _____

Typed/Printed Name: _____

"Earning Community Confidence Through Excellence in Service"

DISTRICT ONE
JENNIFER HILL

DISTRICT TWO
ELAINE RENICK

DISTRICT THREE
JIMMY CONNER

DISTRICT FOUR
LINDA STEWART

DISTRICT FIVE
WELTON G. CADWELL